

3.5 PETROLEUM OIL AND LUBRICANT (POL) USE AND MANAGEMENT

The Contractor is permitted to: fill vehicles or equipment on Dobbins with fuel; add oil or lubricant to vehicles or equipment; and to store and use gasoline, diesel, oil or hydraulic fluid under the scope of this project.

3.5.1 References

- a) Dobbins HAZMAT Plan Dobbins Air Reserve Base Hazardous Materials Emergency Response (HAZMAT) Plan (May 2001 or Current)

3.5.2 Reserved

3.5.3 Hazardous Material Requirements

The Contractor is required to follow hazardous material requirements outlined in Paragraph 3.3 in addition to POL requirements outlined in Paragraph 3.5 for the following POL products.

- a) Gasoline
- b) Jet Fuel (JP-8)

3.5.4 Storage

3.5.4.1 The Contractor shall not store any quantity of fuel or other petroleum products in tanks or bladders larger than 5 gallons without government approval.

3.5.4.2 The Contractor shall provide and use secondary containment for storage of fuel and other petroleum products. Material used in the establishment of secondary containment shall be inert and impervious to the material being stored. Secondary containment shall be able to contain at least the contents of the largest container for which it is employed plus ten percent. Separate containment shall be provided for incompatible materials. If the tank and secondary containment are exposed to rainfall, the following additional requirements apply:

3.5.4.2.1 Sufficient freeboard shall be incorporated to ensure the containment will hold the complete contents of the tank plus ten percent plus 6" of rainfall.

3.5.4.2.2 Storm water drained off the secondary containment must be inspected and monitored before draining out of the containment. If POL is present, the water must be disposed of in accordance with the Dobbins Waste Management Plan and cannot be discharged to the environment.

3.5.4.2.3 Inspection and draining of any accumulated water shall be conducted at least once a week or after rain fall events.

3.5.5 Transfer Operations

In all transfer activities, the Contractor shall maintain segregation of incompatible materials.

3.5.6 Vehicle Capacity

The Contractor is prohibited from using any vehicle for the transportation of fuel or other POL products on Dobbins ARB with a total tank capacity of

greater than 2,000 gallons per storage compartment.

3.5.7 Spill Control and Cleanup

The Contractor shall be responsible for the cleanup and disposal of all spilled POL products. This includes all materials use to contain and absorb the spill. The Contractor shall maintain a stock of spill cleanup material, e.g. absorbent material, on hand at all locations where fuel or petroleum products are stored and transferred. The Contractor's stock of spill cleanup materials shall be adequate to clean up the total amount of products being stored by the Contractor or the total amount being transferred by the Contractor. Spills of POL products shall be managed in accordance with the current HAZMAT Plan for Dobbins ARB. Disposal of wastes generated from spill cleanup shall be the contractors responsibility and be in accordance with paragraph 3.2 and 3.8 of this section.